

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 101

Dated: 01/05/2022

It is certified that an inspection team headed by PHED
(Name of Officers with designation) from Ashok RAMNARATH Assistant Engineer
(Name of Department/ Office) inspected the Public Health Engineering Department
(Name & Address of the school) on 01/05/25 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one year

Signature with Seal: 
Name : अशोक रामनारात्र
Designation : सहायक अभियंता
जन स्वास्थ्य अभियांत्रिक विभाग
दित्तराम उपराज्यमंडल तुरीम, कोट

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

.....
S. R. Public Sr. Sec. School,
Behind Dabaniya Station,
Kola (Ray.)

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



OFFICE OF THE SENIOR CHEMIST
REGIONAL LABORATORY, PHED, KOTA, RAJASTHAN
 PHED Campus, AKELGARH KOTA-324010



Test Report
(CHEMICAL & BACTERIOLOGICAL EXAMINATION OF WATER)

Desp. No. : 1962

Dated : 28/3/25

Issued to:

Principal

*S R Public Sr. Sec. School
Kota*

District: Kota
Block/City: Kota

Sample No: Collected by Lab

Ref ID	23		Sample Code No.	PC-234 PB-171
Reference : Letter No.		113	Source :	RO
Reference Date:		17.03.25	Source Location :	School Campus
Date of Receipt :		17.03.25	Habitation/Ward No. :	-
Sample ID	28		Village/Colony/Nagar :	-
Name of Sample Collector:	Manmohan Suman		Gram Panchayat/City Area :	-
Designation of Sample Collector:	-		Date of Collection :	17.03.25
Latitude of Location			Start Date of Examination :	17.03.25
Longitude of Location			End Date of Examination :	20.03.25
Elevation of Location				

Test Parameters	IS-10500:2012(RA 2018)		Sample Report No.	Test Values
	Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	References Method:	
1 pH At Temp. 25° C	6.5 to 8.5	No relaxation	[IS 3025, P-11], 2022	7.48
2 Turbidity	1.0	5.0	-	0.46
3 Taste	Not Defined	Not Defined	-	-
4 Odour	Unobjectionable	Unobjectionable	-	-
5 Total Alkalinity (as CaCO ₃) mg/l	200	600	[IS 3025, P-23], 1986 (RA 2019)	30
6 Total Hardness (as CaCO ₃) mg/l	200	600	[IS 3025, P-21], 2009 (RA 2019)	60
7 Calcium (as Ca ⁺⁺) mg/l	75	200	[IS 3025, P-40], 1991 (RA 2019)	-
8 Magnesium (as Mg ⁺⁺) mg/l	30	100	[IS 3025, P-46], 1994 (RA 2019)	-
9 Chloride (as Cl ⁻) mg/l	250	1000	[IS 3025, P-32], 1988 (RA 2019)	20
10 Nitrates (as NO ₃ ⁻) mg/l	45	No relaxation	[APHA, Ed24, 4500-B] NO ₃ : 2022	4
11 Fluoride (as F ⁻) mg/l	1.0	1.5	[IS 3025, P-60], 2008 (RA 2019)	0.0307
12 Total Dissolved Solids (TDS) mg/l At 180° C	500	2000	[IS 3025 P-16/APHA, Ed24, 2510-B1 Cond 2022]	173
13 Total Coliform (MPN/100ml)	Nil	Nil	-	Nil

(*ADL= Above detection limit; BDL= Below detection limit)

**REPORT IS NOT VALID FOR
JUDICIAL AND COMMERCIAL
PURPOSE**

Authorized Signatory
TPM/3/25
 (Tarun Kumar Jain)
 Senior Chemist

NOTE:

- This test report shall not be reproduced except in full, unless permission for the reproduction of an approved abstract has been obtained from the Senior Chemist, REGIONAL LABORATORY PHED, KOTA (Rajasthan).
- This test report relates only to the samples/items submitted to the laboratory for test.
- This report is not valid for legal cases/legal purposes.
- Sample will be preserved only for 15 days from date of receipt.
- Measurement of uncertainty and standard methods will be provided to customer on demand.

Telephone : 0744-2470946

E-mail: lab.kot.phed@rajasthan.gov.in

-----End of the Report-----




कार्यालय नगर निगम कोटा दक्षिण (राज०)

क्रमांक :— ननिको(द.) / जनस्वा. / 2025 / १८७

दिनांक : २०/६/२०२५

प्रमाण—पत्र

प्रमाणित किया जाता है कि एस. आर. पब्लिक, सीनियर सैकण्डरी स्कूल, 42, लार्ज स्केल इण्डस्ट्रीयल एरिया, डकनिया स्टेशन के पीछे, कोटा, राजस्थान में स्थित है। उक्त विद्यालय का वातावरण स्वच्छ व साफ व प्रदूषण मुक्त है तथा सफाई की अनुकूल व्यवस्था है। यह प्रमाण पत्र एक वर्ष के लिये मान्य होगा।


स्वारथ्य अधिकारी
नगर निगम, कोटा

नगर निगम कोटा दक्षिण